

SOUTHERN SAN JOAQUIN MUNICIPAL UTILITY DISTRICT



Kern County, California

NOTICE TO PLANHOLDERS

Addendum 2

**SPECIFICATIONS NO. 26-02
CARATAN RECHARGE PIPELINE**



September 11, 2026

Sign and return this notice with your Proposal.

Firm Name _____
By _____
Title _____
Date _____

By signing the cover sheet, Contractor certifies that it has reviewed the contents of the subject addendum and that its proposal has been prepared taking into consideration the changes made by said addenda.

Addendum 2
SPECIFICATIONS NO. 26-02
CARATAN RECHARGE PIPELINE

Specification No. 26-02 is hereby changed and/or clarified as follows.

1. Questions Received prior to 5 PM, September 10th, 2026.

- a. *Question:* What is the duration for this project? I see we have a 30 Calander day window for the diversion structure work however I wasn't able to determine the total project duration.


Answer: The completion date is January 31, 2027, per Special Condition D-3.

- b. *Question:* What lengths are the 48" CML&C pipe coming in?

Answer: The pipe vendor shop drawings are not available. Assume the lengths will come in 20 ft spools maximum.

- c. *Question:* Will they have holdbacks and if so, what is the length of the holdback?

Answer: The pipe will have 6" ends uncoated where welded joints are required. The Contractor shall anticipate 9 welded joints. The Butt strap materials will be provided by the pipe supplier. Modify the butt strap detail as follows:





NOT TO SCALE

Answer: CLSM is specified as an alternative backfill at the discretion of the Contractor.

- h. *Question:* Who is responsible (cost, scheduling, etc.) for the Worker Environmental Awareness Program (WEAP) Training per the Biological Resource Requirements, Page D-24 of the project specifications?

Answer: The District.

- i. *Question:* Per Table 09900A-Coating Schedule, CS-7 and CS-8, Since all buried fittings (bends, tapping sleeves, etc.) and buried valves will be greased and wrapped with Polyethylene sheets, is the fusion bonded epoxy lining still required?

Answer: Yes.

- j. *Question:* Where is the District provided materials (slide gate, CMLC Pipe, and flow meters) being stored and the estimated distance from the project location?

Answer: The materials are stored at the District office, address on the plans. The route and distance can be estimate from Google Earth.

- k. *Question:* Has the basin work, SSJMUD 26-01 started already? If not, when is the estimated start date for the project and will we be able to coordinate with the grading contractor for the placement of the 2 – 18” and 1 – 24” turn-out?

Answer: The major basin work (moving dirt) should be completed prior to your NTP. Some remnants may be performed coincident with your work (finish grading, slope trimming placement of Aggregate surfacing). You will be required to coordinate your work where there may be conflicts.

2. Attachments

- a. Planholders List

Southern San Joaquin Municipal Utility District
SSJMUD 26-02 – Caratan Recharge Pipeline
Planholders List – Addendum 2

ISSUED TO	CONTACT
OneDrive link	
SSJMUD	
Kern County Builders Exchange	sgeissel@kcbex.com admin@kcbex.com sydney@kcbex.com
Dodge Data and Analytics	dodge.bidding@construction.com support@construction.com projectdata@construction.com jane.walters@construction.com
Construct Connect	maria.delfino@constructconnect.com
Unified Field Services Corp	Timothy Jacober Tim_Jacob@ufsc.us Project Manager Cherie Layton cherie_layton@ufsc.us 6906 Downing Avenue Bakersfield, CA 93308 (661) 378-3162 Cell (661) 858-8223 Office
Southern San Joaquin Municipal Utility District	Connie Andrade conniea@ssjmud.org
Utility Concrete Products, LLC	Alex Poe, Technical Sales apoe@utilityconcrete.com (815) 640-4429
Granite Construction Company	Sarah Pearse 3005 James Road, Bakersfield, CA, 93308 Sarah.Pearse@gcinc.com 661-387-7741
Specialty Construction Inc.	Tom Seidel bids@specialtyconstruction.com SHERI SHAMBLIN BID COORDINATOR SPECIALTY CONSTRUCTION INC. License #619361 A,B Business Address: 645 Clarion Court, San Luis Obispo, CA 93401 Office: (805) 543-1706
NovaTech	Sandy Jenkins (she/her) 315-813-7887 sjenkins@novatechnologiesgrp.com www.novatechnologiesgrp.com 1401 Nobel Street Sainte-Julie, QC J3E1Z4, Canada

Southern San Joaquin Municipal Utility District
SSJMUD 26-02 – Caratan Recharge Pipeline
Planholders List – Addendum 2

ISSUED TO	CONTACT
Superior Ag Construction	Nathan Delk ndelk@macgeneralengineering.com 638 Industrial Drive PO BOX 178 Exeter, CA 93221 O: 559-592-1888 F: 559-592-1899 C: 559-310-0216
HPS Mechanical	Alyssa Ortiz AOrtiz@hpsmechanical.com Office: 661.397.2121 Direct: 661.617.8222
Whitaker Construction Group	Randy Walters rwalters@wcgroupinc.com 2752 Concrete Ct. Paso Robles, CA 93446 (805) 226-4020
S&B Sons	Alan Bednersh projects@sbsonsus.com 661.541.5191
Rain for Rent	Rob Morgan fwmorgan@rainforrent.com 559.352.2089
West Valley Construction	Sean Morgan smorgan@wvcc.com 661.671.2260
Nicholas Construction, Inc.	Alex Silicz alex@ncidigs.com 661.619.7417 (cell)
Tarra General Engineering LLC	Joel Vargas ajvargas@tgellc.com 559.333.6067